



Date: August 20, 2007
To: All Participating Bidders
From: Diane Cowan

ADDENDUM NO. 1 TO CONTRACT #2007-06,
35 Kw DIESEL GENERATOR

Please note the following three (3) changes to our Page 10 and 11 specifications:

	<u>Original Statement</u>	<u>Change to</u>
Page 10:	Voltage-120/208, 3 phase, wye, 4 wire	120/240 V, single phase, 3 wire
Page 11:	System-3 phase, 3 wire or 4 wire Voltage-208 VAC	Single phase, 3 wire 240 V, single phase

We apologize for the oversight. The bid opening date of September 5th, 2007 at 2 p.m. remains the same.

If you have any questions concerning this information, please contact me.