



**UNIVERSITY AREA JOINT AUTHORITY**

1576 Spring Valley Road  
State College, PA 16801

Date: August 30, 2007  
To: All Participating Bidders  
From: Diane Cowan

**ADDENDUM NO. 3 TO CONTRACT #2007-06,**  
**35 Kw DIESEL GENERATOR**

Please supply generator that is capable of starting simultaneously two (2) Flygt submersible sewage lift pumps. Each are rated at 3.9 hp, 230 single phase, 60 cycle, 17.0 amp.

We apologize for the oversight. The bid opening date of September 5<sup>th</sup>, 2007 at 2 p.m. remains the same.

If you have any questions concerning this information, please contact me.