



Date: February 16, 2012
To: All suppliers
From: Diane Ruth

ADDENDUM #2
CONTRACT #2012-02, PIPE AND FITTINGS FOR 2012

Please refer to pages 10, 11 and 12 of the bid document for quantity changes noted in red:

1260 ft. **BASIS OF BID** - 36" DR25, 165 PSI, C905 PVC (Polyvinyl Chloride) pipe

OR

ALTERNATE - 36" DR21, 200 PSI, C905 PVC (Polyvinyl Chloride) pipe

13 each EBAA 36" Series 2000 Mega Lug Mechanical Joint Restraint – PVC Pipe with accessories, standard MJ Gasket (Bolts and Nuts included)

1 each Ductile Iron Fitting, 36" Mechanical Joint 45 degree bend, SSB CL350, without accessories, AWWA C153

1 each Ductile Iron Fitting, 36" Mechanical Joint 22.5 degree bend, SSB CL350, without accessories, AWWA C153

1 each Ductile Iron Fitting, 36" Mechanical Joint 11.25 degree bend, SSB CL350. without accessories, AWWA C153

We apologize for any confusion this may have caused. The bid opening date of March 1st, 2012 at 2 pm remains the same.

If you have any questions concerning this information, please contact me.