

UNIVERSITY AREA JOINT AUTHORITY
STATE COLLEGE
CENTRE COUNTY, PENNSYLVANIA

CONTRACT #2016-01

BID, CONTRACT & SPECIFICATIONS FOR
CONVEYOR BELT REPLACEMENT

JULY 2016

INVITATION TO BID

Sealed Bids will be received by the University Area Joint Authority in their offices at 1576 Spring Valley Road, State College, Centre County, Pennsylvania, 16801 until 10 am prevailing time, August 10th, 2016, at which time they will be opened and read aloud. The bids are to be for the purchase of:

1. CONTRACT #2016-01, CONVEYOR BELT REPLACEMENT

Instructions to Bidders, Specifications and Forms of Contracts may be obtained at the office of the Authority. All Bids shall be on the Bid Form and shall be irrevocable for a period of sixty (60) days after the opening of Bids.

The University Area Joint Authority reserves the right to waive any defects, errors, omissions, mistakes, informalities, to accept any bid or combination of bids that are deemed to be in the best interest of the Authority, and to reject any or all bids.

Please be advised that the University Area Joint Authority will not discriminate against any interested firms or individuals in regard to race, creed, color, sex, age, handicap or national origin in the selection process.

Please contact Diane Ruth at 814-238-5361 between the hours of 8 a.m. and 4 p.m. with questions.

University Area Joint Authority

Cory R. Miller, Executive Director

Dated: July 2016

FORM OF BID

FOR: CONVEYOR BELT REPLACEMENT

TO: University Area Joint Authority
1576 Spring Valley Road
State College, Pa. 16801

Contractor:

Pursuant to and in accordance with your advertisement for bids dated July 30th, and August 3rd, 2016 and the Instructions to Bidders relating thereto, the Undersigned having carefully examined the Specifications and other Contract Documents hereby proposes to furnish CONVEYOR BELT REPLACEMENT in accordance with the Specifications and all Addenda issued by the Owner and mailed to the Undersigned a minimum of three (3) working days prior to the opening of Bids whether received by the undersigned or not, complete, and ready for use, for the price set forth in the following Schedule.

CONTRACT #2016-01
SCHEDULE NO. 1

CONVEYOR BELT REPLACEMENT

For furnishing all supplies as specified in Section No. 2 of these Specifications, the **lump sum price** is:

Additions or Deductions for Modifications and/or Exceptions to the Specifications:

- | | |
|----------|----------|
| 1. _____ | \$ _____ |
| 2. _____ | \$ _____ |
| 3. _____ | \$ _____ |

BIDDER'S REPRESENTATION

The undersigned hereby represents as follows:

1. That their Bid is made without connection with any person, firm, or corporation making a bid for the same CONVEYOR BELT REPLACEMENT, and is in all respects fair and without fraud or collusion;
2. That no officer, agent or employee of the University Area Joint Authority is personally interested directly or indirectly in their Contract or the compensation to be paid hereunder; and,
3. That no representation, statement or statements, oral or in writing, has induced them to enter into their contract excepting only those contained in the Contract Documents or made a part hereof by its terms.

The undersigned hereby designates as their office to which any notice of acceptance may be sent. Please provide company name, address, contact, phone and email address.

Their bid may be withdrawn at any time prior to the scheduled time for opening of bids or any authorized postponement thereof.

WITNESS:

INDIVIDUAL:

_____ (SEAL)

WITNESS:

PARTNERSHIP:

_____ (SEAL)

By: _____ (SEAL)

_____ (SEAL)

WITNESS:

FIRM OR CORPORATION:

_____ (SEAL)

By: _____

If a corporation, give State of Incorporation using the phrase, "A Corporation Organized under the Laws of

_____."

If a partnership, give names of partners, using also, the phrase, "Co-partners trading and doing business under the firm name of

_____."

If an individual, using a trade name, give individual name, using also, the phrase, "An individual doing business under the firm name of

_____."

SECTION NO. 1
INSTRUCTIONS TO BIDDERS

1. The attached Specifications set forth for CONVEYOR BELT REPLACEMENT. Any change, variation or substitution of equal product must be clearly stated in the bid.
2. All Contracts must be executed on forms furnished by the Authority.
3. All Bids shall be sealed in an envelope plainly marked "SEALED BID FOR CONVEYOR BELT REPLACEMENT #2016-01" UNIVERSITY AREA JOINT AUTHORITY.
4. All supplemental instructions will be in the form of written Addenda to the bid and Specifications, which if issued, will be mailed to all prospective Bidders not later than three (3) working days prior to the date fixed for the opening of the bids.
5. The successful Bidder will be responsible for the payment of all Excise, Sales and Use Taxes and all other taxes required by law on all materials, tools, apparatus, equipment, fixtures, services, uses and incidentals which they purchase or use for the purpose of fulfilling the work of their Contract, and they shall include all amounts required for such taxes within the item prices in their Bid. No additional payment will be made to cover such taxes. Each Bidder shall thoroughly familiarize themselves before submitting a Bid with all laws requiring the payment of such taxes.

Attention is directed to the fact that under existing provisions of the Pennsylvania 1963 Tax Act for Education and regulations promulgated by the Pennsylvania Department of Revenue, items of tangible personal property used or consumed directly in the rendition of a public utility service (including a sewer system) are exempt from tax under said Act upon proper application for the certificate of exemption. Bidders are further advised that, upon proper application, an Excise Tax Exemption Certificate will be provided to the successful Bidder.

CONTRACT

THIS AGREEMENT made and entered into this _____ day of _____ by and between the University Area Joint Authority, hereinafter known as the Owner, Party of the First Part, and _____ a _____ known as _____, existing under the laws of _____, hereinafter called the CONTRACTOR, Party of the Second Part.

WITNESSETH, that the Parties hereto for the consideration stated mutually agree as follows:

ARTICLE I – SCOPE OF WORK:

The Contractor agrees to furnish the specified CONVEYOR BELT REPLACEMENT and perform all work necessary for or incidental to, and to perform all other obligations imposed by their contract for the complete work, all in strict accordance with the CONTRACT DOCUMENTS as prepared by the Authority, attached hereto or referred to herein, all of which are made a part of and designated as follows:

- a. Notice to Bidders
- b. Instructions to Bidders
- c. Form of Bid
- d. Specifications for CONVEYOR BELT REPLACEMENT

ARTICLE I – DISPOSAL OF CONTRACT:

The CONTRACTOR shall keep the CONTRACT under their own control and shall not sell, transfer or assign or otherwise dispose of the CONTRACT or any portion thereof or their right, title or interest herein to any person, firm or corporation without the express written consent of the OWNER.

IN WITNESS WHEREOF, the parties hereto have caused the signatures of their proper officers to be affixed hereunto on the day and year first above written.

CONTRACT #2016-01 CONVEYOR BELT REPLACEMENT

UNIVERSITY AREA JOINT AUTHORITY

By: _____
 Chairman

ATTEST:

 Secretary

CONTRACTOR

By: _____

ATTEST:

SECTION NO. 2 SPECIFICATIONS

The following indicates the MINIMUM specifications of our CONVEYOR BELT REPLACEMENT

- CONVEYOR BELT REPLACEMENT must be completed no later than September 30th, 2016.
- (1) One 24" wide x 159' long, 2 ply, 220 piw belting with 1/8" x 1/16" MORS cover and shop installed mechanical splice
- (1) One 24" wide x 540' long, 2 ply, 220 piw belting with 1/8" x 1/16" MORS cover and shop installed mechanical splice
- Bidder will supply all materials and equipment to complete the job.
- Contractor must remove all used materials from site upon completion.
- Bidder must clearly define scope of work and timeline, providing a minimum of (1) one week notice to UAJA staff.
- Bid submittal must include all costs associated with this project.
- Warranty – 1 year minimum for belts and splices. Must also clearly state response time for repairs.
- ***The successful bidder must provide proof of Workman's Compensation Insurance.***
- ***The successful bidder must provide a Certificate of Insurance naming UAJA as an additional insured and providing proof of commercial auto and general liability coverage at a minimum of \$1,000,000.00 per occurrence.***
- All materials must be guaranteed to meet UAJA specifications. Any deviation from the above specifications will be executed only upon written order to UAJA, and will become an extra charge over and above the contract only after UAJA approval. All agreements are contingent upon strikes, accidents or delays beyond our control.
- Faxed or emailed bids will not be accepted.
- All bidders must provide a minimum of 3 work references (unless you have had previous work experience with UAJA).