

SPECIFICATIONS (clarified)

The following indicates the MINIMUM requirements including all genuine parts, accessories, equipment and safety features considered standard, whether mentioned herein or not, of our TWO (2) PRIMARY CLARIFIER AIR COMPRESSORS

The bid is to include the following items:

- Receipt of the TWO PRIMARY CLARIFIER AIR COMPRESSORS must be no later than October 6th, 2017.
- Bidder must include shop drawings with their bid packet.
- Bidder to supply Two (2) Rotary Screw PRIMARY CLARIFIER AIR COMPRESSORS each capable of producing AT A MINIMUM 165 SCFM at 70 PSI continuously. Site conditions are an approximately elevation of 950 feet and design should be for worst case weather conditions of 100 Deg F and 85% Relative Humidity.
- Compressors shall be designed and supplied as a complete package with all necessary equipment, including but not limited to the following components: inlet filter, air compression element, drive motor, aftercooler with integral moisture separator (**Integrated refrigerated air dryer**), oil cooler, cooling fan, motor starter, microprocessor regulation and control system (**variable speed type**). All components shall be mounted on a common solid base frame and fully enclosed with a sound attenuating enclosure.
- Units shall be manufactured by a qualified manufacturer who has been manufacturing AIR COMPRESSORS for at least ten (10) years.
- Successful bidder is required to clearly define scope of work and timeline, providing a minimum of one (1) week notice to UAJA Staff of shipment of units to the site.
- Units shall be complete and provided with consumables for each unit (filters, oil, lubricants, tools, etc.) for one year of continuous operation. Bidder will also provide spare parts list and consumables list for each unit, for UAJA's use with submittals.
- Bidder is required to provide Field Startup Services after installation by UAJA. These field startup services shall consist of a minimum of four (4) hours of commissioning and four (4) hours of training on the operation and maintenance of the unit.
- One (1) year MINIMUM Warranty on the units. Must also clearly state response time for repairs.
- Bid submittal must include all costs associated with this project, inclusive of field startup services and consumables/spare parts.
- The successful bidder must provide proof of Workman's Compensation Insurance.
- The successful bidder must provide a Certification of Insurance naming UAJA as an additional insured and providing proof of commercial auto and general liability coverage at a minimum of \$1,000,000.00 per occurrence.
- All bidders must provide a minimum of 3 work references (unless they have had previous work experience with UAJA).
- Faxed or emailed bids will not be accepted.