

1. WARNING TAPE TO READ "CAUTION: BURIED RECLAIMED WATER BELOW"

RECLAIMED WATER MAIN TRENCH DETAIL

NOT TO SCALE




RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PENNSYLVANIA

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	1
CADD- KEC	•
CHECKED-	SHEET NO.
SCALE- AS SHOWN	1 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562

TI TO THE TO THE PARTY OF THE PARTY OF THE CASE WAS A MANAGEMENT OF THE PARTY OF TH



PROVIDE CONCRETE ENCASEMENT WHERE THE DISTANCE BETWEEN THE INVERT OF THE UTILITY AND THE WATERLINE IS LESS THAN 18", OR WHERE SHOWN ON THE PLANS.

UTILITY CROSSING DETAIL


NOT TO SCALE

UNIVERSITY AREA JOINT AUTHORITY

RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	2
CADD- KEC	-
CHECKED-	SHEET NO.
SCALE- AS SHOWN	2 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562



1. IF EXTENSIONS ARE NECESSARY CONTRACTOR SHALL SET "PLUMB" AND ALIGN PROPERLY FOR ACCESS TO OPERATING NUT.

TYPICAL GATE VALVE AND VALVE BOX DETAIL

NOT TO SCALE




RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PENNSYLVANIA

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	І з
CADD- KEC	°
CHECKED-	SHEET NO.
SCALE- AS SHOWN	3 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562

THE AMERICAN CONTRACT OF THE PROPERTY OF THE P



1. DRAIN HOLE IN HYDRANT MUST NOT BE OBSTRUCTED W/ CONCRETE

FIRE HYDRANT ASSEMBLY DETAIL

NOT TO SCALE

UNIVERSITY AREA JOINT AUTHORITY


RECLAIMED WATER STANDARD DETAIL FOR UNIVESITY AREA JOINT AUTHORITY

CENTRE COUNTY

PENNSYLVANIA

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	1 4
CADD- KEC	7
CHECKED-	SHEET NO.
SCALE- AS SHOWN	4 % 12
DATE- JUNE 2015	PROJECT 001178.0562

Column | The TOCATORING CARACTER CARACT






RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	5
CADD- KEC	
CHECKED-	SHEET NO.
SCALE- AS SHOWN	5 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562



1. CONTRACTOR TO PROVIDE VALVE AND VALVE BOX

FROST-FREE YARD HYDRANT DETAIL


NOT TO SCALE




RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	6
CADD- KEC	'
CHECKED-	SHEET NO.
SCALE- AS SHOWN	6 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562





NOTE: DELETE SUMP IN AREAS WITH HIGH WATER TABLE. SECTIONAL ELEVATION

AIR RELEASE/VACUUM VALVE


NOT TO SCALE



RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	7
CADD- KEC	<i>'</i>
CHECKED-	SHEET NO.
SCALE- AS SHOWN	7 of 12
DATE- JUNE 2015	PROJECT 001178.0562



- 1) MOUNT SIGN AT RIGHT ANGLE TO DIRECTION OF TRAFFIC FLOW.
- 2) ALL SIGN POSTS WITHIN ROAD RIGHTS-OF-WAY MUST MEET PennDOT SPECIFICATIONS FOR BREAKAWAY POSTS.

RECLAIMED WATERLINE LOCATION/I.D. PADDLE




FOR

CENTRE COUNTY

PENNSYLVANIA

_
2
62

RECLAIMED WATER STANDARD DETAIL UNIVERSITY AREA JOINT AUTHORITY



(SERVICE LINES 2" DIA AND LESS)

WATER SERVICE LINE DETAIL

NOT TO SCALE



RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY


CENTRE COUNTY

PROJ. MGR BRB	DRA
DESIGN- BRB	
CADD- KEC	
CHECKED-	SHE
SCALE- AS SHOWN	9

PENNSYLVANIA

9 EET NO. of 12

JUNE 2015 PROJECT 001178.0562




METER PIT W/ PRESSURE REDUCING VALVE DETAIL (LOW FLOW) NOT TO SCALE



RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	10
CADD- KEC	'0
CHECKED-	SHEET NO.
SCALE- AS SHOWN	10 ∘ 12
DATE- JUNE 2015	PROJECT 001178.0562



(SERVICE LINES >2" DIA)

WATER SERVICE LINE INSTALLATION DETAIL

NOT TO SCALE




RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY


PENNSYLVANIA

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	11
CADD- KEC	
CHECKED-	SHEET NO.
SCALE- AS SHOWN	11 of 12
DATE- JUNE 2015	PROJECT 001178.0562

TY



PLAN



NOTES:

- 1. ALL INTERNAL PIPING SHALL BE FLANGED DUCTILE IRON PIPE, CLASS 52.
- 2. METER PIT DESIGN BY PRECAST CONCRETE MANUFACTURER.
- 3. CONTRACTOR TO INSTALL PIPE SUPPORTS AS REQUIRED.
- 4. PRECAST CONCRETE METER PIT TO BE MINIMUM 7'-6" X 6'-0 X 6'-0"HIGH
- 5. PIPING, VALVES, METERS AND APPURTENANCES TO BE SIZED BASED ON FLOW PROJECTIONS.

METER PIT DETAIL (HIGH FLOW)

NOT TO SCALE



RECLAIMED WATER STANDARD DETAIL FOR UNIVERSITY AREA JOINT AUTHORITY

CENTRE COUNTY

PROJ. MGR BRB	DRAWING NO.
DESIGN- BRB	12
CADD- KEC	12
CHECKED-	SHEET NO.
SCALE- AS SHOWN	12 of 12
DATE- JUNE 2015	PROJECT 001178.0562